



NATIONAL TESTING LABORATORIES, LTD.

556 South Mansfield, Ypsilanti, MI 48197-5166
(440) 449-2525 • Fax (440) 449-8585



ANALYTICAL REPORT

PAGE 1 OF 5 SAMPLE CODE: 702758

Date: 03/03/09 Report #: 702758 Laboratory ID #: 0055

Client: TRUE ALASKA BOTTLING CO.
4500 SAWMILL CREEK RD
SITKA, AK 99835-

Date Collected: 01/26/09
Time Collected: 07:00
SOURCE: BLUE LAKE
SITKA, AK
SOURCE WATER
TEMP=1C pH=6.2

Date received at lab: 01/28/09 Time received at lab: 12:35
Collected by : B.MCCLUNG

The results herein conform to NELAC standards, where applicable, unless otherwise narrated in the body of the report. Test results were calculated on a wet weight basis. The uncertainty of the test results are available upon request.

PLEASE NOTE: Holding Times were exceeded for pH, Odor, Color, Foaming Agents, Turbidity, Ortho Phosphate, Nitrate and Nitrite.

NOTE: "*" The MCL (Maximum Contaminant Level) or an established guideline has been exceeded for this contaminant.
"ND" This contaminant was not detected at or above our lower reporting limit (LRL).
"NA" Not Analyzed.

Table with 7 columns: Fed Id #, Analysis Performed, Method, MCL (mg/l), LRL, Level Detected, Anal Date. Rows list various metals like Aluminum, Antimony, Arsenic, Barium, Beryllium, Boron, Cadmium, Calcium, Chromium, Copper, Iron, Lead, Magnesium, Manganese, Mercury, Nickel, Potassium, Selenium, Silver, Sodium, Thallium, Zinc.



NATIONAL TESTING LABORATORIES, LTD.

556 South Mansfield, Ypsilanti, MI 48197-5166
(440) 449-2525 • Fax (440) 449-8585



ANALYTICAL REPORT

PAGE 2 OF 5 SAMPLE CODE: 702758

Table with columns: Fed Id #, Analysis Performed, Method, MCL (mg/l), LRL, Level Detected, Anal Date. Includes data for Inorganic chemicals - other, and physical factors.

Table with columns: Fed Id #, Analysis Performed, Method, MCL (mg/l), LRL, Level Detected, Anal Date, Anal Time. Includes data for various chemical tests like Nitrate, Nitrite, Phosphate, pH, Turbidity, etc.

** Denotes Secondary Maximum Contaminant Level (SMCL)



NATIONAL TESTING LABORATORIES, LTD.

556 South Mansfield, Ypsilanti, MI 48197-5166
(440) 449-2525 • Fax (440) 449-8585



ANALYTICAL REPORT

PAGE 3 OF 5 SAMPLE CODE: 702758

Fed Id #	Analysis Performed	Method	MCL (mg/l)	LRL	Level Detected	Anal Date

Organic chemicals - trihalomethanes:						

2942	Bromoform	524.2	---	0.0005	ND	01/30/09
2943	Bromodichloromethane	524.2	---	0.0005	ND	01/30/09
2941	Chloroform	524.2	---	0.0005	ND	01/30/09
2944	Dibromochloromethane	524.2	---	0.0005	ND	01/30/09
2950	Total THMs	524.2	0.080	0.0005	ND	01/30/09

Organic Chemicals-Volatiles:

2990	Benzene	524.2	0.005	0.0005	ND	01/30/09
2993	Bromobenzene	524.2	---	0.0005	ND	01/30/09
2430	Bromochloromethane	524.2	---	0.0005	ND	01/30/09
2214	Bromomethane	524.2	---	0.0005	ND	01/30/09
2422	n-Butylbenzene	524.2	---	0.0005	ND	01/30/09
2428	sec-Butylbenzene	524.2	---	0.0005	ND	01/30/09
2426	tert-Butylbenzene	524.2	---	0.0005	ND	01/30/09
2982	Carbon Tetrachloride	524.2	0.005	0.0005	ND	01/30/09
2989	Chlorobenzene	524.2	0.1	0.0005	ND	01/30/09
2216	Chloroethane	524.2	---	0.0005	ND	01/30/09
2210	Chloromethane	524.2	---	0.0005	ND	01/30/09
2965	2-Chlorotoluene	524.2	---	0.0005	ND	01/30/09
2966	4-Chlorotoluene	524.2	---	0.0005	ND	01/30/09
2408	Dibromomethane	524.2	---	0.0005	ND	01/30/09
2968	1,2-Dichlorobenzene	524.2	0.6	0.0005	ND	01/30/09
2967	1,3-Dichlorobenzene	524.2	---	0.0005	ND	01/30/09
2969	1,4-Dichlorobenzene	524.2	0.075	0.0005	ND	01/30/09
2212	Dichlorodifluoromethane	524.2	---	0.0005	ND	01/30/09
2978	1,1-Dichloroethane	524.2	---	0.0005	ND	01/30/09
2980	1,2-Dichloroethane	524.2	0.005	0.0005	ND	01/30/09
2977	1,1-Dichloroethene	524.2	0.007	0.0005	ND	01/30/09
2380	cis-1,2-Dichloroethene	524.2	0.07	0.0005	ND	01/30/09
2979	trans-1,2-Dichloroethene	524.2	0.1	0.0005	ND	01/30/09
2983	1,2-Dichloropropane	524.2	0.005	0.0005	ND	01/30/09
2412	1,3-Dichloropropane	524.2	---	0.0005	ND	01/30/09
2416	2,2-Dichloropropane	524.2	---	0.0005	ND	01/30/09
2410	1,1-Dichloropropane	524.2	---	0.0005	ND	01/30/09
2228	cis-1,3-Dichloropropene	524.2	---	0.0005	ND	01/30/09
2224	trans-1,3-Dichloropropene	524.2	---	0.0005	ND	01/30/09
2992	Ethylbenzene	524.2	0.7	0.0005	ND	01/30/09



NATIONAL TESTING LABORATORIES, LTD.

556 South Mansfield, Ypsilanti, MI 48197-5166
(440) 449-2525 • Fax (440) 449-8585



ANALYTICAL REPORT

PAGE 4 OF 5 SAMPLE CODE: 702758

Fed Id #	Analysis Performed	Method	MCL (mg/l)	LRL	Level Detected	Anal Date

Organic chemicals - volatiles						

2246	Hexachlorobutadiene	524.2	---	0.0005	ND	01/30/09
2994	Isopropylbenzene	524.2	---	0.0005	ND	01/30/09
2030	4-Isopropyltoluene	524.2	---	0.0005	ND	01/30/09
2964	Dichloromethane	524.2	0.005	0.0005	ND	01/30/09
2248	Naphthalene	524.2	---	0.0005	ND	01/30/09
2998	Propylbenzene	524.2	---	0.0005	ND	01/30/09
2996	Styrene	524.2	0.1	0.0005	ND	01/30/09
2986	1,1,1,2-Tetrachloroethane	524.2	---	0.0005	ND	01/30/09
2988	1,1,2,2-Tetrachloroethane	524.2	---	0.0005	ND	01/30/09
2987	Tetrachloroethene	524.2	0.005	0.0005	ND	01/30/09
2991	Toluene	524.2	1	0.0005	ND	01/30/09
2420	1,2,3-Trichlorobenzene	524.2	---	0.0005	ND	01/30/09
2378	1,2,4-Trichlorobenzene	524.2	0.07	0.0005	ND	01/30/09
2981	1,1,1-Trichloroethane	524.2	0.2	0.0005	ND	01/30/09
2985	1,1,2-Trichloroethane	524.2	0.005	0.0005	ND	01/30/09
2984	Trichloroethene (TCE)	524.2	0.005	0.0005	ND	01/30/09
2218	Trichlorofluoromethane	524.2	---	0.0005	ND	01/30/09
2904	Trichlorotrifluoroethane	524.2	---	0.0005	ND	01/30/09
2414	1,2,3-Trichloropropane	524.2	---	0.0005	ND	01/30/09
2418	1,2,4-Trimethylbenzene	524.2	---	0.0005	ND	01/30/09
2424	1,3,5-Trimethylbenzene	524.2	---	0.0005	ND	01/30/09
2976	Vinyl Chloride	524.2	0.002	0.0005	ND	01/30/09
2251	Methyl-Tert-Butyl-Ether	524.2	---	0.0005	ND	01/30/09
2247	Methyl Ethyl Ketone	524.2	---	0.005	ND	01/30/09
2997	o-Xylene	524.2	---	0.0005	ND	01/30/09
2995	m-Xylene(1)	524.2	---	0.0005	ND	01/30/09
2962	p-Xylene(1)	524.2	---	0.0005	ND	01/30/09
2955	Xylenes (Total)	524.2	10			



NATIONAL TESTING LABORATORIES, LTD.

556 South Mansfield, Ypsilanti, MI 48197-5166
(440) 449-2525 • Fax (440) 449-8585



ANALYTICAL REPORT

PAGE 5 OF 5 SAMPLE CODE: 702758

Table with columns: Fed Id #, Analysis Performed, Method, MCL (mg/l), LRL, Level Detected, Anal Date. Lists various pesticides and their detection results.

Volatile Organic Chemicals - method 504.1

Table with columns: Fed Id #, Analysis Performed, Method, MCL (mg/l), LRL, Level Detected, Anal Date. Lists 1,2-Dibromo3chloropropane and 1,2-Dibromoethane.

504.1- Date Extracted: 02/02/09
505 - Date Extracted: 02/02/09
508.1- Date Extracted: 02/03/09

These test results may be used for compliance purposes as required.

- (1) Due to the limitations of EPA Method 524.2, m and p isomers of xylene are reported as an aggregate.
(2) Total PCB's consists of the following Aroclors, each with a LRL of 0.0005 mg/L; 1016, 1221, 1232, 1242, 1248, 1254 and 1260.

Signature of David J. Vesey, Lab Director



ANALYTICAL REPORT

PAGE 1 OF 2 SAMPLE CODE: 96645

Date: 02/18/09 Report #: 96645 Laboratory ID #: E86035

Client: TRUE ALASKA BOTTLING CO.
 4500 SAWMILL CREEK RD
 SITKA, AK 99835-

Date Collected: 01/26/09
 Time Collected: 07:00
 SOURCE: BLUE LAKE
 SITKA, AK
 SOURCE WATER
 TEMP=1c pH=6.2

Date received at lab: 01/28/09 Time received at lab: 09:30

Collected by : B.MCCLUNG

The results herein conform to NELAC standards, where applicable, unless otherwise narrated in the body of the report. Test results were calculated on a wet weight basis. The uncertainty of the test results are available upon request.

NOTE: "*" The MCL (Maximum Contaminant Level) or an established guideline has been exceeded for this contaminant.
 "ND" This contaminant was not detected at or above our lower reporting limit (LRL).
 "NA" Not Analyzed.

Fed Id #	Analysis Performed	Method	MCL (ug/l)	LRL	Level Detected	Anal Date
1024	Cyanide	4500CN-F	200	15	ND	02/03/09
2910	T. Phenols	420.1	---	1	ND	02/04/09
1039	Perchlorate	314.0	---	0.2	NA	
2021	Carbaryl	531.1	---	1.5	ND	02/15/09
2022	Methomyl	531.1	---	1.5	ND	02/15/09
2043	Aldicarb sulfoxide	531.1	7	2.0	ND	02/15/09
2044	Aldicarb sulfone	531.1	7	1.5	ND	02/15/09
2047	Aldicarb	531.1	7	2.0	ND	02/15/09
2066	3-Hydroxycarbofuran	531.1	3	1.0	ND	02/15/09
2036	Oxamyl	531.1	200	1.5	ND	02/15/09
2046	Carbofuran	531.1	40	2.5	ND	02/15/09
2045	Metolachlor	525.2	---	0.20	ND	02/09/09
2076	Butachlor	525.2	---	0.20	ND	02/09/09
2077	Propachlor	525.2	---	0.20	ND	02/09/09
2356	Aldrin	525.2	---	0.20	ND	02/09/09
2070	Dieldrin	525.2	---	0.20	ND	02/09/09
2015	Methoxychlor	525.2	40	0.20	ND	02/09/09
2595	Metribuzin	525.2	---	0.20	ND	02/09/09
-2595	Molinate	525.2	---	0.04	ND	02/09/09
2035	Di(2-ethylhexyl)adipate	525.2	400	0.20	ND	02/09/09
2274	Hexachlorobenzene	525.2	1	0.20	ND	02/09/09
2039	Di(2-ethylhexyl)phthalate	525.2	6	0.5	ND	02/09/09
2306	Benzo(A)pyrene	525.2	0.2	0.20	ND	02/09/09
2037	Simazine	525.2	4	0.20	ND	02/09/09



ANALYTICAL REPORT

Page 2 of 2 Sample Code: 96645

Fed Id #	Analysis Performed	Method	MCL (ug/l)	LRL	Level Detected	Anal Date
2034	Glyphosate	547	700	6.00	ND	02/05/09
2033	Endothall	548.1	100	9.00	ND	02/11/09
2032	Diquat	549.2	20	1.00	ND	02/11/09
525.2	DATE EXTRACTED	02/03/09				
548.1	DATE EXTRACTED	01/30/09				
549.2	DATE EXTRACTED	01/30/09				

These test results may be used for compliance purposes as required.

 Ronald Lyons, Lab Director



ANALYTICAL REPORT

PAGE 1 OF 1 SAMPLE CODE: 96653

Date: 02/13/09 Report #: 96653 Laboratory ID #: E86035

Client: TRUE ALASKA BOTTLING CO.	Date Collected: 01/26/09
4500 SAWMILL CREEK RD	Time Collected: 07:00
SITKA, AK 99835-	SOURCE: BLUE LAKE
	SITKA, AK
	SOURCE WATER
	TEMP=1c pH=6.2

Date received at lab: 01/29/09 Time received at lab: 09:30
 Collected by : B.MCCLUNG

The results herein conform to NELAC standards, where applicable, unless otherwise narrated in the body of the report. Test results were calculated on a wet weight basis. The uncertainty of the test results are available upon request.

NOTE: "*" The MCL (Maximum Contaminant Level) or an established guideline has been exceeded for this contaminant.
 "ND" This contaminant was not detected at or above our lower reporting limit (LRL).
 "NA" Not Analyzed.

Fed Analysis Performed Id #	Method	MCL (ug/l)	LRL	Level Detected	Anal Date
2110 Silvex (2,4,5-TP)	515.3	50	1.0	ND	02/11/09
2105 2,4-D	515.3	70	1.5	ND	02/11/09
2031 Dalapon	515.3	200	12.0	ND	02/11/09
2440 Dicamba	515.3	---	0.5	ND	02/11/09
2041 Dinoseb	515.3	7	3.5	ND	02/11/09
2326 Pentachlorophenol	515.3	1	0.5	ND	02/11/09
2040 Picloram	515.3	500	1.0	ND	02/11/09
2625 Bentazon	515.3	---	1.5	ND	02/11/09

515.3 DATE EXTRACTED 02/04/09

These test results may be used for compliance purposes as required.

 Ronald Lyons, Lab Director



ANALYTICAL REPORT

PAGE 1 OF 1 SAMPLE CODE: 96650

Date: 02/06/09 Report #: 96650 Laboratory ID #: E86035

Client: TRUE ALASKA BOTTLING CO.
 4500 SAWMILL CREEK RD
 SITKA, AK 99835-

Date Collected: 01/26/09
 Time Collected: 07:00
 SOURCE: BLUE LAKE
 SITKA, AK
 SOURCE WATER
 TEMP=1c pH=6.2

Date received at lab: 01/28/09 Time received at lab: 09:30
 Collected by : B.MCCLUNG

The results herein conform to NELAC standards, where applicable, unless otherwise narrated in the body of the report. Test results were calculated on a wet weight basis. The uncertainty of the test results are available upon request.

NOTE: "*" The MCL (Maximum Contaminant Level) or an established guideline has been exceeded for this contaminant.
 "ND" This contaminant was not detected at or above our stated detection limit.

Fed Analysis Id # Performed	MCL (mg/l)	Sample Analysis Number	Method Result	MDL	Anal Date
1003 Nitrogen-Ammonia as (N)	---	96650	ND	4500NH3F 0.25	02/03/09

 Ronald Lyons, Lab Director

ANALYTICAL RESULTS

Project: 1127796
Pace Project No.: 304562

Sample: 702758 **Lab ID: 304562001** Collected: 01/26/09 07:00 Received: 01/29/09 15:20 Matrix: Drinking Water
PWS: Site ID: Sample Type:

- Comments:
- SOURCE WATER, Blue Lake, Sitka, AK
 - Sample Number 702758
 - True Alaska Bottling
 - Sample collected 1/26/09 @ 0700 by Brent McClung

Parameters	Method	Act ± Unc (MDC)	Units	Analyzed	CAS No.	Qual
Gross Alpha	EPA 900.0	0.388 ± 0.603 (1.32)	pCi/L	02/10/09 08:37		
Gross Beta	EPA 900.0	0.589 ± 0.686 (1.46)	pCi/L	02/10/09 08:37		
Radium-226	EPA 903.1	0.369 ± 0.417 (0.662)	pCi/L	02/13/09 13:45		
Radium-228	EPA 904.0	0.219 ± 0.381 (0.836)	pCi/L	02/18/09 17:15		
Total Uranium	ASTM D5174.97	0.0847 ± 0.003 (0.210)	ug/L	02/18/09 11:09	7440-61-1	



EMSL Analytical, Inc.
 107 Haddon Ave., Westmont, NJ 08108

Phone: (856) 858-4800 Fax: (856) 858-4960 Email: westmontaslab@EMSL.com

Attn: **J. Ruput**
National Testing Laboratories, Inc.
6571 Wilson Mills Road
Cleveland, OH 44143

Customer ID: NTL178
 Customer PO: 14630
 Received: 01/29/09 10:30 AM
 EMSL Order: 040902603

Fax: Project: Phone: (440) 449-2525

EMSL Proj:
 Analysis Date: 1/30/2009
 Report Date: 1/30/2009

**Determination of Asbestos Structures in Water Performed by the 100.2 Method
 (EPA/600/R-94/134)**

Sample ID	Sample Prep Date	# Fibers Asbestos	# Fibers Non-Asbestos	Type(s) Of Asbestos	Analytical Sensitivity (MFL)	Confidence Limits	Concentration Of Asbestos Fibers (MFL)	Comments
702758 040902603-0001	1/29/09	0	0		0.20	0.00-0.74	<0.20	

Analyst(s) _____
 Katie Boucher (1)

Stephen Siegel, CIH, Laboratory Manager
 or other approved signatory

Sample collection and containers provided by the client, acceptable bottle blank level is defined as $\leq 0.01 \text{MFL} > 10 \mu\text{m}$. ND=None Detected. This report may not be reproduced, except in full, without written permission by EMSL Analytical, Inc. The test results contained within this report meet the requirements of NELAC unless otherwise noted. This report relates only to the samples reported above. Samples received in good condition unless otherwise noted.

ACCREDITATIONS: NJ Lab ID: 04006, NYS ELAP Lab ID: 10872, NVLAP 101048-0, FL Lab ID: E87788



LABORATORY REPORT

Client: National Testing Laboratories
Attn: Susan Henderson
6571 Wilson Mills Road
Cleveland, OH 44143

Report: 219800
Priority: Standard Written
Status: Final

Source Name: Blue Lake

Lab Cert#: M-IN035

Samples Submitted: One drinking water sample

City: Sitka, AK

National Testing #: 1127796-0197

Collected Date: 01/26/09

Received Date: 01/29/09

Table with 6 columns: PARAMETER, SDWA Method, MDL *, Results, Analysis Date, Lab Number. Rows include Perchlorate (ug/L) and Conductivity (uS/cm).

NA = Not applicable

* UL has demonstrated it can achieve this method validation limit in reagent water, but cannot document them in all sample matrices.

Note: Sample container was provided by the client.

We appreciate the opportunity to provide you with this analysis. If you have any questions concerning this report, please do not hesitate to call us at (574) 233-4777.

Note: This report may not be reproduced, except in full, without written approval from Underwriters Laboratories Inc. (UL).

Signature lines for Reviewed By and Finalized By.

Signature lines for Date with handwritten dates 2/11/09 and 2.11.09.



FREE-COL LABORATORIES

11618 COTTON ROAD
MEADVILLE, PENNSYLVANIA 16335
PHONE: (814) 724-6242
FAX: (814) 333-1466
EMAIL: service@freecol.com

Accredited Lab ID#
Free-Col: 20-00073
Modern Erie: 25-03459

Certificate Of Analysis

Delivery Group ID: 2009:0000981

1 Sample(s) are included in this Delivery Group.

Company Name: National Testing Lab.

Date Received 1/29/2009

Time Received: 11:30

Delivered By: Fed Ex

6571 Wilson Mills
Cleveland OH 44143

P.O. 1127796

Project Name: True Alaska Bottling

Printed on 02/19/2009 at 03:36PM

Sample ID: 2009:0000981-1

Client's Sample ID: 702758

Date Sampled: 1/26/2009 Time Sampled: 07:00

Date Received: 1/29/2009

Analyte	Result	Units	Date Analyzed	Start Time	Analyst	Method	Source
---------	--------	-------	---------------	------------	---------	--------	--------

General Chemistry

Sulfuric Acid

1 mg/L 02/11/09 10:30 Semroc

Sulfuric Acid was performed by SM 0512.02.

Company Name: True Alaska Bottling, Sitka AK

Source Name: Blue Lake, Sitka, AK

Sample Temperature: 1 Degrees C

Field pH 6.2



RTI LABORATORIES, INC.

31628 Glendale St.
Livonia, Michigan 48150
TEL: 734.422.8000
FAX: 734.422.5342
Website: www.rtilab.com

Case Narrative

WO#: 0902442
Date: 2/26/2009

CLIENT: National Testing Laboratories, Ltd.
Project: 702758, Blue Lake, Sitka, AK

This report in its entirety consists of the documents listed below. All documents contain the RTI Work Order Number assigned to this report.

1. Paginated Report including: Case Narrative, Analytical Results and Applicable Quality Control Summary Reports.
2. A Cover Letter that immediately precedes the Paginated Report.
3. Paginated copies of the Chain of Custody Documents supplied with this sample set.

Concentrations reported with a J flag in the Qual field are values below the reporting limit (RL) but greater than the established method detection limit (MDL). There is greater uncertainty associated with these results and data should be considered as estimated. These analytes are not routinely reviewed nor narrated below as to their potential for being laboratory artifacts.

Concentrations reported with an E flag in the Qual field are values that exceed the upper quantification range. There is greater uncertainty associated with these results and data should be considered as estimated.

Any comments or problems with the analytical events associated with this report are noted below.

Based on the concentration of sulfate in the sample and the pH of the sample there is no sulfuric acid in the sample.



RTI LABORATORIES, INC.

31628 Glendale St.
Livonia, Michigan 48150
TEL: 734.422.8000
FAX: 734.422.5342
Website: www.rtilab.com

Analytical Report

(consolidated)

WO#: 0902442

Date Reported: 2/26/2009

CLIENT: National Testing Laboratories, Ltd.
Project: 702758, Blue Lake, Sitka, AK
Lab ID: 0902442-001
Client Sample ID 702758, Blue Lake, Sitka, AK

Collection Date: 1/26/2009 7:00:00 AM

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
NITROGEN/PHOSPHORUS PESTICIDES				E507	E507	Analyst: MB
Diazinon	ND	0.62		µg/L	1	2/25/2009 11:30:02 AM
Fenthion	ND	0.62		µg/L	1	2/25/2009 11:30:02 AM
Parathion, ethyl	ND	0.12		µg/L	1	2/25/2009 11:30:02 AM
Parathion, methyl	ND	0.12		µg/L	1	2/25/2009 11:30:02 AM
Surr: Triphenylphosphate	123	70-130		%REC	1	2/25/2009 11:30:02 AM
INORGANIC ANIONS				E300.0		Analyst: BV
Sulfate	2.0	0.60		mg/L	6	2/18/2009 11:09:00 PM
PH				A4500-H+B		Analyst: JE
pH	7.0	0	H	pH Units	1	2/19/2009 3:00:00 PM

Qualifiers:

- *X Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Detection Limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- M Manual Integration used to determine area response
- PL Permit Limit
- S Spike Recovery outside accepted recovery limits

RTI Laboratories

26-Feb-09

Lab Order: 0902442
Client: National Testing Laboratories, Ltd.
Project: 702758, Blue Lake, Sitka, AK

DATES REPORT

Sample ID	Client Sample ID	Collection Date	Matrix	Test Name	TCLP Date	Prep Date	Analysis Date
0902442-001A	702758, Blue Lake, Sitka, AK	1/26/2009 7:00:00 AM	Drinking Water	Nitrogen/Phosphorus Pesticides		2/20/2009	2/25/2009
0902442-001B				Inorganic Anions			2/18/2009
				pH			2/19/2009